

	Handling, Storage & Use of compressed gas cylinder GAS CYLINDER STORAGE CHECKLIST	AMNS/Project/SOP/HSEM/04/F01
		Rev : 00
		Date: 02 Dec 2022
		Page 1 of 1

Project Name:		Date:	
Location:			
Name of Contractor			

SN	Check Points	OK/ Not OK / NA	Remarks
1	Is the cylinder storage area shall be clearly demarked appropriately away (30 meter from the hot work area) from the work site.		
2	Are the cylinders are stored in a covered shed which is well ventilated, protected against direct sun light and heat?		
3	Is the shed area and its approach is properly graded?		
4	Is the access to the area restricted to authorized persons only?		
5	Are the cylinders stored in an upright position and secured (chained)?		
6	Are different types of cylinders stored separately with proper permanent barrier and with proper identification labelling?		
7	Are the empty cylinders and full cylinders stored separately and are properly labelled?		
8	Are all the cylinders fitted with correct type of valve cap / guard all the time?		
9	Are all flammable gas cylinders kept away from the oxygen cylinders (minimum of 20 feet or 6 meter)?		
10	Is the electrical fittings meet zone II classification in the cylinder storage area?		
11	Are cautionary boards displayed near the storage area?		
12	Are appropriate type and sufficient numbers of Fire Extinguishers provided and maintained all the time?		
13	Are the cylinders shifted with cylinder trolley?		
14	Do all cylinder have cylinder caps / valve guard?		

Inspected By:

Name:

Signature